



United States Department of the Interior

NATIONAL PARK SERVICE
Fire Island National Seashore
120 Laurel Street
Patchogue, NY 11772

Review and Comments on Building/Zoning Permit Application

Applicant(s):

Owner: Chris Davis

Agent: Michelle Quatralo

Tax Map #:

985.80-2.6

Application No.:

Case #22 on November 4, 2015

Zoning Authority:

Brookhaven

Community:

Point O' Woods

Object (Yes/No):

Yes

If Objection status is "Yes", property will be subject to the condemnation authority of the Secretary of the Interior, if built as proposed, or previously built with or without permits beyond allowable standards.

Reason for Objection: 36 CFR Part 28.12(d)

Objection Type:


Exceeds 35% maximum lot occupancy

Comments:

The National Park Service objects to the overdevelopment of this property as the lot occupancy is 43.8% exceeding the Federal Zoning Standard lot occupancy of 35%. In order to conform to the Federal Standards, the Seashore suggests decreasing the decks around the dwelling.

Review of this application for construction or variance request within the Fire Island National Seashore is made in accordance with 36 C.F.R. Part 28, Federal Zoning Standards for Fire Island National Seashore.


Superintendent


Date

Cc: Applicant